MAITHRI GEO-CONSULTANCY

17, 2nd Cross, Ramakrishnaiah Layout, Malagala Main Road,
Bangalore - 91. Phone - 23283108 Mobile - 9901709701

Ground water investigation report

Ref _____ Date 09.06.17

Name Assistant Executive Engineer

Address Yelahanka Sub division
BBMP

Location 4th cross Vivekanand Road Malleta. Road
Yelahanka ward no - 1

Topography Moderate Slope Soil type Granite & Sandy

Rock type Granite & Shale Aquifers 90 - 100 - 140 - 170

Nos. (1)

RECOMMENDATIONS

Depth 240 - 290 Mts	Depth 240 - 290 Mts
Casing 50 - 60 Mts	Casing 50 - 60 Mts
Yield 2000 - 2200 Gph.	Yield 2000 - 2200 Gph.

Remarks _____

Although best site has been suggested for drilling, no guarantee of success can be given. We will not be liable for any loss in any way, to the party or person, irrespective of the well drilled at the site recommended, being failure.

Asst Executive Engineer
Yelahanka Sub. Divison
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Purushottam Bhat
M.Sc. Applied geology
Hydrologist

MAITHRI GEO-CONSULTANCY

17, 2nd Cross, Ramakrishnaiah Layout, Malagala Main Road,
Bangalore - 91. Phone - 23283108 Mobile - 9901709701

Ground water investigation report

Ref _____ Date 11.06.17

Name Assistant - Executive Engineer.

Address Yelahanka Sub Division
B.B.M.P

Location Shoulcoseppa Lay Out - Kogilu main Road
Maruthinagara Yelahanka Ward NO-1

Topography Moderate Slope. Soil type Gravel & Sandy

Rock type Granite & Gneiss Aquifers 80 - 90 - 130 - 160

Nos. (2)

RECOMMENDATIONS

Depth 230 - 280 Mts	Depth 230 - 280 Mts
Casing 40 - 50 Mts	Casing 40 - 50 Mts
Yield 1800 - 2000 G.P.H	Yield 1800 - 2000 GPH

Remarks _____

Although best site has been suggested for drilling, no guarantee of success can be given. We will not be liable for any loss in any way, to the party or person, irrespective of the well drilled at the site recommended, being failure.

Asst. Executive Engineer
Yelahanka Sub. Divison
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Purushottam Bhat
M.Sc. Applied geology
Hydrologist

MAITHRI GEO-CONSULTANCY

17, 2nd Cross, Ramakrishnaiah Layout, Malagala Main Road,
Bangalore - 91. Phone - 23283108 Mobile - 9901709701

Ground water investigation report

Ref _____ Date 11.06.17

Name Assistant Executive Engineer

Address Yelahanka Sub Division
B.B.M.P.

Location 8th cross Kurlappa layout - Malleshwaram
Yelahanka Ward No. 1

Topography Moderate Slope Soil type Grind & Sandy

Rock type Grind & Sleeze Aquifers _____

Nos. (3) RECOMMENDATIONS

Depth 250 – 300 Mts	Depth 250 – 300 Mts
Casing 60 – 70 Mts	Casing 60 – 70 Mts
Yield ~~2~~ 1700 – 1900 GPH	Yield 1700 – 1900 GPH

Remarks _____

Although best site has been suggested for drilling, no guarantee of success can be given. We will not be liable for any loss in any way, to the party or person, irrespective of the well drilled at the site recommended, being failure.

Asst. Executive Engineer
Yelahanka Sub-Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Purushottam Bhat
M.Sc. Applied geology
Hydrologist